



**DIVISION OF TOURISM, CULTURE AND TRANSPORTATION,
12 SANGSTER'S HILL, SCARBOROUGH, TOBAGO.**

Tel: 639-2125/4636 Fax: 639-5432

www.visittobago.gov.tt

Addendum: Installation of Sub Panel box at the Icon museum. This panel box is to supply a flow of electricity to the water pump.

Notes: The following should be done by a licensed electrician and must conform to the correct electrical building codes.

Description	Unit	Quantity	Rate	Amount
A. Procure and mount onto concrete wall 100- 150- amps electrical sub panel box. Installation should be placed no less than a foot away from the main service panel.				
B. Strip wires at main service box: to acquire a ground, neutral, and two (2) hot wires (black & red) connected to a 240 Volt double pole breakers and route carefully to enclose by use of chunking.				
C. Electrical panel must have a minimum of 36 inches of clearance in front of the panel, 30 inches of clearance across the face of the panel, and a minimum of				

78 inches above the floor.				
D. Make good any defects created during installation, and cart away all surplus materials from area.	Item	Allow		