



TOBAGO HOUSE OF ASSEMBLY
**Division of Food Security, Natural Resources, the Environment, Sustainable
and Development**
Shirvan Administrative Complex, Shirvan Road
Shirvan, Tobago
TEL# (868) 639-5994/2234, 660-7152
FAX (868) 639-1746

Questions & Answers

INVITATION TO TENDER

For

REPAIR WORKS TO

CULLODEN FISH FACILITY

We at the Division for the abovementioned ITT, do hope the responses provided help in clearing up any misunderstanding to all participants.

The following questions with responses are hereby provided.

Appendix A - Bill of Quantities; Section 7 - MEP Works particularly Electrical Installation

Question 1: What is the recommended quantity of flood lights needed? It is for the illumination of all four sides of the building?

Answer: The total number of flood lights needed are (2 in number). Please note that there were flood lights in the past and the poles are existing. Nonetheless, kindly allow for 400watts LED slim flood lights.

Question 2. Additionally, are the wall socket's being placed behind the both walls, the one behind the ice bin and the opposite wall?

Answer: These constitute the additional outlets stated in "item 7 (a)". Yes! allow for the sockets to be placed in the wall.

Additionally:

In accordance with this item: please note that upgraded lights within the building are to be "Vapor LED Lights" and lengths are to be similar to existing.

DFSNRESD 2023/24 -002

-END-